

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1 10</div>	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0003</div>		3. EFFECTIVE DATE <div style="text-align: center;">14-Dec-2004</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">W16ROE-4302-4908</div>		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, NEW YORK ATTN:CENAN-CT ROOM 1843 26 FEDERAL PLAZA NEW YORK NY 10278		CODE <div style="text-align: center;">W912DS</div>		7. ADMINISTERED BY (If other than item 6) <div style="text-align: center; font-weight: bold;">See Item 6</div>			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X 9A. AMENDMENT OF SOLICITATION NO. W912DS-05-B-0002			
				X 9B. DATED (SEE ITEM 11) 22-Nov-2004			
				10A. MOD. OF CONTRACT/ORDER NO.			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The solicitation is amended as follows: 1. To incorporate and reissue revised drawings; 2. To incorporate and reissue revised specifications; 3. To incorporate a revised bid schedule (Section 00010); 4. To incorporate contractor(s) submitted questions and provide answers to such, herein. The bid opening date remains unchanged. NOTE: OFFERORS MUST ACKNOWLEDGE RECEIPT OF THIS AMENDMENT BY THE DATE SPECIFIED IN THE SOLICITATION (OR AS AMENDED) BY ONE OF THE FOLLOWING METHODS: IN THE SPACE PROVIDED ON THE SF1442, BY SEPARATE LETTER, OR BY TELEGRAM, OR BY SIGNING BLOCK 15 BELOW. FAILURE TO ACKNOWLEDGE AMENDMENTS BY THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR BID IN ACCORDANCE WITH THE LATE BID, LATE MODIFICATIONS OF BIDS OR LATE WITHDRAWAL OF BIDS (FAR14.304). Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 14-Dec-2004	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0003**AMENDMENT 0003 TO DRAWINGS AND SPECIFICATIONS FOR FY 05 Military Entrance Processing Station (MEPS), Niagara Falls Air Reserve Station – W912DS-05-B-0002****TO BIDDERS**

The following changes shall be made to the drawings and specifications.

DRAWINGS

1. Reference is made to Amendment 2, **DRAWINGS**, Paragraph 1. The following DRAWINGS listed as **REVISED** and **REISSUED** under amendment 2 is corrected as follows to include drawing C-10:
 - a. S-001 General Notes (Structural)
 - b. S-102 Steel Framing Plan
 - c. S-106 Canopy Details
 - d. A-101 Floor Plan
 - e. A-500 Wall Sections
 - f. A-700 Enlarged Casework Plans and Details
 - g. C-10 Site Plans
2. The following DRAWINGS have been **REVISED** but not **REISSUED**:
 - a. A-300, Building Sections; **ADD** the following note to Sections “A” and “B” for the Reception Desk:

“Note: Lettering over the Reception Desk shall be:
Upper Case: 200mm (8”) high Stainless Steel
Lower Case: 125mm (5”) high Stainless Steel
All letters shall be 8mm (1/4”) thick. Each letter shall be mounted to GWB.
Contractor to submit shop drawings, sample of letters, and means of fastening for approval.”
 - b. A-503, Curved Wall Details; **REPLACE**, under item 4 in the Material Legend the word “Limestone” with “Stone”.

c. E-01, Symbols, Abbreviations & Electrical Site Plan; **ADD** the following to the column entitled Abbreviations: “S_v 10-position, wall-mounted rotary switch for speaker volume control.”

3. The following DRAWINGS have been **REVISED** and **REISSUED**:

- a. A-300 Building Sections
- b. A-503 Curve Wall Details
- c. A-504 Miscellaneous Details
- d. A-601 Door Schedule
- e. M-701 AHU-1, 2, 3 Control Schematic

SPECIFICATIONS

1. The following SPECIFICATION SECTIONS have been **ADDED** and are provided in their entirety herein:

- a. **Section 09100**, Metal Support Assemblies.

2. The following SPECIFICATIONS SECTIONS have been **DELETED** in their entirety: **NONE**

The following SPECIFICATIONS have been **REVISED** but not **REISSUED**:

a. **Section 08120**, Aluminum Doors and Windows; Paragraph 2.3 – Fabrication, subparagraph 2.3.7, ADD the following: “Provide wood grain finish to partition framing and doors at rooms numbered 104 and 105 to match wood paneling in room number 104. Wood grain paint finish shall be applied to inside and outside surfaces.”

BIDDER’S QUESTIONS AND GOVERNMENT REPLY

(Questions that may be of general interest of all bidders/Government and that are not readily answered by the proceeding changes will appear below. These questions may have been paraphrased or altered to represent several questions regarding the same subject and/or clarify and simplify the question(s). Questions and answers are issued to the Offerors/Bidders for information only.)

Question (Q): Drawing A-102 indicates ceiling tiles as 600 x 600. Specification Section 09510, 2.1.1 tells us 600 x 1200. Which is correct?

Response (R): Refer to amendment 2, revising tile size specified to 600 x 600 mm.

Q. Drawing A-605, Metal Studs. The drawing tells us the size. There is no specification Section to tell us the gage. Please advise. The information should be in specification 09100.

R: Section 09100 added per this amendment.

Q. Drawing A-10, Seismic Considerations are indicated for Roof, ceiling and walls. Is there any to be considered for the floor?

R: None is show or required.

Q. Section 2/A-502A - Gable end blocking scales a \pm 75mm x 600mm (3" x 24") sub-fascia and a \pm 25mm x 350mm (1" x 14") fascia. Elevations/A-200 gable ends appear significantly smaller. Please provide a clear detail of gable end blocking.

R: Gable ends fascia boards shall be 50 x 300mm.

Q: Typical Exterior Wall, Section 1, Drawing A-500 indicates 200 mm CMU. Typical interior CMU partition detail on Drawing A-605 indicates 203 mm CMU. The standard metric CMU is 190 mm in width. Please advise if the intent is to use the 190 mm block or if specialty sizes are required.

R: The intent is to use standard size available: i.e., 200 and 203mm may be considered nominal size and 190mm the actual size.

Q: Drawing A-503, Material Legend, Note 4, Precast Limestone Sill; Please provide a specification for this material.

R: Refer to section 03451, Cast Stone for requirements. Note change to note 4 of the material legend issued above per this amendment.

Q: Drawing A-300, Sections A& B show "Reception Desk" Letters. Cannot Locate Details/Spec.

R: Note changes to drawing A-300, above, issued per this amendment.

Q: Security Gate Details on sheet A-704: Is this the "Brick Pillar" (2 Shown) on plan C-2? If not, Please clarify both. **R: "Brick Pillars (Typ.)" is indicated on drawing C-2 (grid location F8). There are two pairs of pillars shown and required for this project.**

Q: Are fire extinguishers to be included in the work? **R: R: Drawing, A-100, has been revised and reissued under amendment #2, to show locations of fire extinguishers (FE) and fire extinguisher cabinets (FEC).**

Q: Is the bottom of the footing for the site screens to be 2'-10" below grade per detail 5/A504? **R: No. The minimum bottom of Footing is 5 feet below finished grade.**

Q: Are the shelves in Room 161 same as in room 148? **R: Yes.**

Q: Accent canopy option is still not included on the bid form. **R: Bid schedule revised per amendment #3.**

Q: What type of pipe material is used for Storm? Please provide pipe trench detail.

R: Piping must meet that specified in section 02630, part 2. Trench shall be per specification section 02300.

Q: To the west of storm structure "I5" is a proposed elevation of 565.50. This would put a 30' deep depression here. Please revise.

R: Elevation (Drawing grid location F-9) is incorrect and should read 595.50.

Q. Specification section 00800, item 42 requires contractor to prepare a SWPP Notice of Intent (NOI) & NOI for NYSDEC. Sheet C-5 has an erosion & sediment control plan. What is required for section 00800, item 42?

R See Response below.

Q: Specification Section 00800 – Special Contract Requirements – Item #42 Stormwater Pollution Prevention Plan, Notice of Intent and Notice of Termination, Drawing C5 – Erosion and Sediment Control

Plan – appears to contain the project requirements for storm water control. Are we to have a PE design an entirely new system or is this design to be used?

If the design provided in the specifications is used, what requirement does the contractor have for the storm water pollution prevention plan, notice of intent, etc.? It is our understanding that the storm water pollution prevention plan generally includes the design of retention ponds, etc., which already seems to be complete. The engineer has also advised that bi-weekly inspections by a PE are generally required to fulfill the requirements of storm water pollution prevention plans. Please advise.

R: The plan in electronic drawing format (Microstation) will be made available to the contractor and his PE for his use and modification if necessary by the Contractor's PE. The Bidders are instructed to see specification sections 01355A and 01356 for further requirements. The Contract is responsible for meeting all permit applications requirements inclusive of any fees. The design provided in the plans, to the best of our knowledge, is compliant with the NYSDEC requirements and should not require significant revision if any.

SECTION 00010 (REVISED) III

Section 00010 - Solicitation Contract Form

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001	BASE BID FFP All work for the FY05 Military Entrance Processing Station (MEPS) as described in the plans and specifications, including all plant, labor and materials, complete and excluding Items Nos. 2, and 3 below and all options. PURCHASE REQUEST NUMBER: W16ROE-4302-4908	1	Lump Sum		

NET AMT

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0002	SITE WORK FFP All work outside the five-foot line of the building perimeter, inclusive of demolition (As defined by the Civil (C-series) drawings, drawings AD-101 and AD-102 and the specifications.	1	Lump Sum		

NET AMT

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0003		1	Lump Sum	\$8,000.00	\$8,000.00

FINAL RECORD DRAWING SUBMISSION

FFP

All work for the Final Record Drawing Submission (See paragraph 10 of Section 00800).

NET AMT

\$8,000.00

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0004		1	Lump Sum		

OPTION

OPTIONAL BID ITEM No. 1

FFP

Provide brick and masonry building sign as shown on drawing A-704, Elevations & Detail B, C & 2, in lieu of the sign shown on drawing A-704, Elevation & Detail A & 1.

NET AMT

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0005		1	Lump Sum		

OPTION

OPTIONAL BID ITEM No. 2

FFP

Parking area, east of MEPS; Resurfacing and, striping and lighting of parking area directly behind (east of) the MEPS.

NET AMT

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0006		1	Lump Sum		
OPTION	OPTIONAL BID ITEM No. 3 FFP Sidewalk connecting MEPS with Gymnasium (Bldg 855) parking area (approx. 85 linear feet of 4' wide sidewalk) and parking lot lighting, as described in Electrical Site Plan Key Note 5.a of drawing E-01.				

NET AMT

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0007		1	Lump Sum		
OPTION	OPTIONAL BID ITEM No. 4 FFP Provide all work landscaping (including sod) and irrigation as shown on drawing C-6, and/or described in the specification. in lieu of seeding for entire site.				

NET AMT

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0008		1	Lump Sum		
OPTION	OPTIONAL BID ITEM No. 5 FFP Two Computer Workstations (CPU, Monitor, keyboard, mouse, and compatible software, etc.) as described in section 15951 of the Specification.				

NET AMT

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0009		1	Lump Sum		
OPTION	OPTIONAL BID ITEM No. 6 FFP Under-floor, radiant heating for the Male and Female Ortho rooms, as shown on drawings M-101 and M-505, and described in the specifications.				

 NET AMT

FOB: Destination

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0010		1	Lump Sum		
OPTION	OPTIONAL BID ITEM No. 7 FFP Four Accent Canopies, suspended in lobby, as shown in Section B "along Y- Axis" on drawing A-300.				

 NET AMT

FOB: Destination

TOTAL BASE BID PRICE: \$ _____

TOTAL BID WITH OPTIONAL BID ITEMS NO. 1 THRU NO. 7: \$ _____

NOTES:

1. The low bidder for purposes of award will be the conforming responsible bidder offering the lowest amount for the Base Bid Item plus all Optional Bid Items.
2. The minimum construction award will be the amount bid for the Base Bid Items.
3. Bidders are required to bid on the Base Bid and all Optional Bid Items or their bids will be rejected.
4. Bidders are reminded that they must bid on the issued plans and specifications as amended. Any deviations, conditions or attachments made by the bidder himself thereto may render the bid non-responsive and be cause for its rejection.

5. Option #1, 2, 3 and 4: At any time prior to 180 calendar days after award of the contract, the Government at its option, may direct the Contractor, by written order, to perform the work and/or services provided under Option #1.
6. Option #5 and 7: At any time prior to 300 calendar days after award of the contract, the Government at its option, may direct the Contractor, by written order to perform the work and/or services provided under Option #5.
7. Option #6: At any time prior to 90 calendar days after award of the contract, the Government at its option, may direct the Contractor, by written order to perform the work and/or services provided under Option #6.
8. Award of any or all of the Optional Bid items will not extend or reduce the contract duration indicated in Paragraph 1 of Section 00800 or elsewhere in the contract documents.

SECTION 00010 - SOLICITATION CONTRACT FORM

CLIN 0010 is added as follows:

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0010		1	Lump Sum		
OPTION	OPTIONAL BID ITEM No. 7 FFP Four Accent Canopies, suspended in lobby, as shown in Section B "along Y- Axis" on drawing A-300.				
NET AMT					

FOB: Destination

INSPECTION AND ACCEPTANCE

The following Acceptance/Inspection Schedule was added for CLIN 0010:

INSPECT AT	INSPECT BY	ACCEPT AT	ACCEPT BY
N/A	N/A	N/A	Government

(End of Summary of Changes)